Licensee	Perisher Blue Pty Ltd
EPL No	2274
Sampling Conducted	19th March 2025
Results Obtained	27th March 2025
Results Published	27th March 2025

Monitoring Point	Pollutant								Monitoring Frequency
	Biochemical oxygen demand	**Faecal Coliforms**	**Nitrogen (ammonia)**	**Nitrogen (total)**	**Oil and grease**	**pH**	**Phosphorous (total)**	**Total Suspended Solids**	
	Milligrams per litre	CFU per 100 millitres	Milligrams per litre	Milligrams per litre	Milligrams per litre	pH	Milligrams per litre	Milligrams per litre	
3 – 20m upstream of discharge to waters	<2	56	0.003	0.15	<1	7.73	0.01	4	Fortnightly between June 1 and 30 September, and quarterly between 1 October and 31 May
4 – 100m downstream of discharge to waters	<2	<1	0.5	1.47	<1	7.69	0.29	5	
5 – Post UV disinfection facility	<2	40	0.005	0.25	<1	7.72	0.08	7	
Point 5 - 100% concentration limit	**30**	**600**	**3**	**15**	**10**	**6.5-8.5**	**0.5**	**35**	
6 – Weir at the end of Wetland System	<2	62	0.003	0.09	<1	7.53	<0.01	4	
Notes:									