| | |
|---|---|
| Licensee | Perisher Blue Pty Ltd |
| EPL No | 2274 |
| Sampling Conducted | 29th October 2025 |
| Results Obtained | 7th November 2025 |
| Results Published | 7th November 2025 |

| Monitoring Point | Pollutant | | | | | | | | Monitoring Frequency |
|---|---|---|---|---|---|---|---|---|---|
| | **Biochemical oxygen demand** | **Faecal Coliforms** | **Nitrogen (ammonia)** | **Nitrogen (total)** | **Oil and grease** | **pH** | **Phosphorous (total)** | **Total Suspended Solids** | |
| | Milligrams per litre | CFU per 100 millitres | Milligrams per litre | Milligrams per litre | Milligrams per litre | pH | Milligrams per litre | Milligrams per litre | |
| **3 – 20m upstream of discharge to waters** | <2 | <2 | 0.7 | 1 | <1 | 7.35 | 0.06 | <2 | Fortnightly between June 1 and 30 September, and quarterly between 1 October and 31 May |
| **4 – 100m downstream of discharge to waters** | <2 | 12 | 0.003 | 0.09 | <1 | 7.95 | <0.01 | 3 | |
| **5 – Post UV disinfection facility** | <2 | <2 | 0 | 1 | <1 | 7.35 | <0.01 | <2 | |
| ***Point 5 - 100% concentration limit*** | **30** | **600** | **3** | **15** | **10** | **6.5-8.5** | **0.5** | **35** | |
| **6 – Weir at the end of Wetland System** | <2 | 14 | 0.002 | 0.1 | <1 | 7.74 | <0.01 | 3 | |
| **Notes:** | | | | | | | | | |