Licensee	Perisher Blue Pty Ltd	
Licensee	Perisiler blue Pty Ltu	
EPL No	2274	
Sampling Conducted	3 rd March 2021	
Results Obtained	17 th March 2021	
Results Published	22 nd March 2021	

Monitoring Results				
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	
Fortnightly between June 1 3 – 20m and 30 upstream September, and	Biochemical oxygen demand	<2		
	Faecal Coliforms	44		
	Nitrogen (ammonia)	<0.1		
	Nitrogen (total)	0.07		
discharge	9.5	Oil and grease	<1	
to waters October and 31 May	рН	7.92		
	Phosphorous (total)	<0.01		
	Total Suspended Solids	<2		
Comments				

Monitoring Results				
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	
4 – 100m downstream of discharge	Fortnightly between June 1 and 30	Biochemical oxygen demand	<2	
		Faecal Coliforms	28	
		Nitrogen (ammonia)	<0.1	
	September, and quarterly	Nitrogen (total)	0.06	
	between 1 October and 31 May	Oil and grease	<1	
		рН	7.62	
		Phosphorous (total)	<0.01	
		Total Suspended Solids	<2	
Comments				

Monitoring Results							
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit		
5 – Post UV disinfection facility	Fortnightly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	3	30	Milligrams per litre		
		Faecal Coliforms	<2	600	Colony forming units per 100 millitres		
		Nitrogen (ammonia)	<0.1	3	Milligrams per litre		
		Nitrogen (total)	1.54	15	Milligrams per litre		
		Oil and grease	<1	10	Milligrams per litre		
		рН	8.01	6.5 – 8.5	рН		
		Phosphorous (total)	0.07	0.5	Milligrams per litre		
		Total Suspended Solids	6	35	Milligrams per litre		
Comments							